

Danish Indoor Climate Labelling Certificate no. 015



Danish Indoor Climate Labelling hereby certifies that the product group

DEKO demountable partitions with wall covering

manufactured by

**DEKO loft+væg p/s
Mårkærvej 11
DK-2630 Taastrup**

has been approved and awarded a labelling licence

The declared indoor-relevant time-value has been determined according to the labelling criteria listed in the following documents issued by the Danish Indoor Climate Labelling:

*Testing and Labelling Criteria for
Interior doors and partitions 2nd edition, 2005
and General Labelling Criteria, 5th edition, 2007*

*The certificate is based on tests of
DEKO wall panel with wall covering*

The certificate is valid 5 years from:

1st September 2010

and is subject to annual renewal by attestation of the Schedule 1-015 to this certificate according to the procedures of Danish Indoor Climate Labelling.

Danish Indoor Climate Labelling may withdraw the rights to use this Certificate in case the company does not meet the requirements.

*This certificate including schedule 1-015 can also be found at:
www.teknologisk.dk/DIM*

For Danish Indoor Climate Labelling

Certification Manager

Date

28.01.2011

Danish Indoor Climate Labelling

Certificate no. 015



Schedule 1-015

Certificate Holder:
DEKO loft+væg p/S
Mårkærvej 11
DK-2630 Taastrup

The certificate was first issued on:
1st September 1995

Labelling Licence Basis:

Danish Indoor Climate Labelling: Testing and labelling criteria for Interior doors and partitions 2nd edition, 2005. The maximum acceptable time-value for partition walls is determined as 100 days. The certificate applies to products considered to be identical with the tested product regarding indoor climate characteristics as specified by the labelling criteria.

Product Characteristics:

The certificate and the declared indoor-relevant time-value comprise exclusively the product group characteristics in relation to odour and irritation of the eyes, nose and upper airways. The declared indoor-relevant time-value is determined on basis of the results of chemical analyses as well as sensory evaluations. Declared time-value:

10 days



Product information Requirements:

The holder of the certificate is required to present the following product information on demand in order to avoid any adverse effects of the product on the indoor climate in practice: product specifications, a list of trade names covered by the certificate, guidelines for projecting, transport, storage, assembly, limitation of applications, cleaning and maintenance.

Monitoring and Renewal of Labelling Licence:

Danish Indoor Climate Labelling monitors and exercises control in accordance with its procedures in force at any time. The certificate is valid only in combination with the present schedule stating the dates of first issue, renewal and expiration, and signed by the Certification Manager of *Danish Indoor Climate Labelling*.

The application for renewal of the labelling licence filed by the certificate holder has been considered according to the requirements of the *Danish Indoor Climate Labelling* with a satisfactory result:

| | | | | |
|-----------------------------------|---|---|--|--|
| Labelling licence Date of renewal | 29.08.2011 | 31.08.2012 | | |
| Attestation of latest renewal |  |  | | |
| Labelling licence Date of expiry | 31.08.2012 | 31.08.2013 | | |

In the event of any discrepancies in the text arising from translation, the Danish text shall prevail.